

Government of Andhra Pradesh
A.P. State Disaster Response and Fire Services Department
Fire No Objection Certificate for Occupancy.

File No: 24513/ELR/MSB/2025

Date: 7/01/2025

Sir/Madam,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Issue of Fire No Objection Certificate for Occupancy to the existing building of **Orchid High School, Dr. No.25-8/1, Hnuman Junction Road, Opp: Saraswathi Temple, Nuzvid, Eluru District**
Regarding.

Ref: Online Application Dt. 03-01-2025

Having satisfied with the reasonable fire safety measures that you have affirmed to have undertaken in your School/College buildings. I hereby grant Occupancy Fire NOC for a period of One year given.

1. Ensured two exits for orderly evacuation of teachers, students and staff in case of any fire incident or emergency.
2. Conducted Mock Drill @ twice a year with participation of teachers, students and preferably in presence some of the parents. And took signatures of staff, teachers, parents, student leaders affirming their familiarity with the equipment and its functioning.

3.Ensured Electrical Safety by observing the following Precautions:

- a. Installation of Miniature Circuit Breakers (MCBs) in all floors.
- b. No Overloading of power sockets in any Educational Building.
- c. 10 years old wiring to be changed, especially where high power consuming appliances such as Air conditioners, Electrical/Mechanical/Computer labs, Data Centers, High-tech labs, X-ray rooms in Medical Colleges, etc., are used.
- d. Grounding/Earthing shall be done.
- e. Lightening conductors may be provided for high-rise buildings exceeding 5 floors.
- f. No High Tension Lines should run inside or in close proximity (< 6 meters) to any Educational institution buildings.
- g. No charging for EV vehicles @ cellars of School/College buildings.

Let the above be tested and certified by any electrical Engineer without regard to any Jurisdiction under employment of Government of Andhra Pradesh once a year.

4. As the ensuring safety is a continuous learning process, we will advise from time to time, practical , modern , reliable but not too hard or that require major modifications to your building structure. And you shall undertake to observe these precautions to enhance fire safety.
5. As a Policy, no retrospective application of rules shall be made for building as long as they comply with that NOC requirements till the life of the building.

6. Any clarifications, you are welcome to meet the DG, Fire Services (9441236448) without appointment in his office as ensuring fire safety with better and affordable technology is a continuous learning and collaborative endeavour.

Your Sincerely


Director General

State Disaster Response & Fire Services
Andhra Pradesh, Vijayawada.

To

The Management of Orchid High School, Dr. No.25-8/1, Hnuman Junction
Road, Opp: Saraswathi Temple, Nuzvid, Eluru District

Copy to the District Educational Officer, Concerned.

Copy to the Secretary Board of Intermediate Education, Andhra Pradesh, Vijayawada

M.P. Rukmini
HEADMISTRESS
ORCHID HIGH SCHOOL
NUZVID-521 201.


Manager
Orchid High School
Nuzvid, Eluru Dist-521-201