

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 68/V/2025

Dated: 15/04/25

It is certified that an inspection team headed byK. Sowmya.....

(Name of Officers with designation) from MO UPHC konerupeta Nuzvid PHED

inspected the ORCHID HIGH SCHOOL opp Sarawati temple, Nuzvid

(Name & Address of the school) on 15/04/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no..... dated 11/04/25

of Water quality monitoring lab Nuzvid (PHED Lab) certified that the

ORCHID HIGH SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 11/04/2026

Signature with Seal:

Name

Designation

Name & Address of the Office / Department : U.P.H.C

K. Sowmya

K. Sowmya

Medical officer

U.P.H.C

To ORCHID HIGH SCHOOL

Nuzvid, Eluru dt. 521 201.

(Name & Address of the Institution)

Konerupeta
MO UPHC
KONERUPETA
NUZVIDU

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

G. Ravi
For SECRETARY
VAISHNAVI EDUCATIONAL SOCIETY
NUZVID

H.P. Rukmini
HEADMISTRESS
ORCHID HIGH SCHOOL
NUZVID-521201.



Government of Andhra Pradesh
RURAL WATER SUPPLY & SANITATION DEPARTMENT
REPORT ON BACTERIOLOGICAL ANALYSIS OF WATER (DRINKING)

Name of the District : Eluru
Name of the Water Testing Laboratory : Water Quality Monitoring Laboratory, Nuzvid.
Received From : PBC Self
Date of Received : 10.4.2025

Date of Issue: 11.4.2025

Report : Bacteriological Analysis Report

S.NO	Name of the Mandal	Gram Panchayat	Habitation	Source Code/ Location	Date of Test	Type of Source	Total coliform bacteria (CFU /100ml)	E.Coli (CFU /100ml)	Residual Free Chlorine	Remarks
				Permissible Limits						
1	Nuzvid	Nuzvid	Nuzvid	orchid High school	10.4.2025	Bore water	0 / 100 ml	0 / 100 ml	0.2	Safe

RESULTS : The sources of received samples are Coliform bacteria and E.Coli is not detected in 100ml of sample .
which is intended for drinking purpose.

Sarada
DEPUTY EXECUTIVE ENGINEER
RWS & S SUB - DIVISION
NUZVID

S. Sarada
Lab.Chemist/Lab.Microbiologist 11/4/25
WQM Laboratory
Sub Division Nuzvid

S. Venkatesh
FOR SECRETARY
VAISHNAVI EDUCATIONAL SOCIETY
NUZVID

H.P. Ravi Kumar
HEADMISTRESS
ORCHID HIGH SCHOOL
NUZVID-521201.



**GOVERNMENT OF ANDHRA PRADESH
RURAL WATER SUPPLY SUBDIVISION LEVEL WATER QUALITY TESTING LABORATORY, NUZVID
WATER ANALYSIS REPORT (CHEMICAL)**

Name of the District : Eluru
Name of the Water T: Sub division level Water Quality Monitoring Laboratory, NUZVID.
Received From self
Date of Collection 10.4.2025
Report : Chemical Analysis Report

Date of Received : 10.4.2025

Date of Issue: 10.4.2025

Sl.No	Name of the Mandel	Name of the Gramapanchayat	Name of the Habitation	Tested Date	Source Code /Location	Type of Source	Turbidity	pH	Electrical Conductivity	Total Dissolved Solids mg/lit	Total Alkalinity as CaCo3	Total Hardness as CaCo3 mg/lit	Calcium as Ca++ mg/lit	Magnesium as Mg++	Chloride as Cl- mg/lit	Fluoride as F- mg/lit	Nitrate as NO3- mg/lit	Sulphate as SO4- mg/lit	Total Iron as Fe mg/lit	Remarks	
1	Nuzvid	Nuzvid	Nuzvid	10.4.2025	orchid High school	Bore water	1	7.62	1250	800	320	448	72	65	272	0.62	4.2	52	0.41	SATISFACTORY	Permissible Limits: Mg/Lt As per IS 10500-2012 Requirement (Acceptable limits) 1.0 to 8.5 Permissible limits in the absence of alternate 5.0 No relaxation

Deputy Executive Engineer
DEPUTY EXECUTIVE ENGINEER
RWB & S SUB - DIVISION
NUZVID

Lab. Chemist/ Lab. Microbiologist
WQM Laboratory
Sub - Division Nuzvid

For Secretary
FOR SECRETARY
VAISHNAVI EDUCATIONAL SOCIETY
NUZVID
HEADMISTRESS
ORCHID HIGH SCHOOL
NUZVID-521201.